

Code of practice for treatment of water in domestic hot water central heating systems

BS7593:2019

BS7593:2019 outlines the best practices for the preparation of the primary circuit of wet central heating systems, this could be initial commissioning or re-commissioning following major works (e.g. boiler replacement) but also the ongoing water treatment to ensure continuing efficiency of the system.



The system should be designed to allow for efficient cleaning and flushing and addition of water treatment chemicals. Particularly, dead legs should be avoided and sufficient drain points should be included.

Good handling and storage of pipework and good practice during installation should limit the ingress of installation debris such as millscale, metal swarf, soldering flux, jointing compounds and grease.

What is the objective of system water treatment?

- A. To minimise corrosion of the system metals
- B. To inhibit the formation of scale and sludge
- C. To inhibit the growth of microbiological organisms
- D. To maintain the engineering design specification and efficiency of the system
- E. To restore energy efficiency of the system where appropriate

Causes of problems in central heating systems

1. Corrosion

Corrosion is generally a process of oxidation of metals which, in a central heating system, can result in restriction of circulation and/or failure of components, for example - perforation of radiators. Corrosion in a central heating system is promoted by the following.

- A. Poor system design and/or installation by creating oxygenated water
- B. Ingress of air e.g. mechanical or poorly soldered joints
- C. Electrolytic (galvanic) action between dissimilar metals
- D. Deleterious materials, e.g. flux residues or jointing compound from the installation process.
- E. Characteristics of the supply water (hard or soft water) and also chlorine content that can promote pitting of ferrous and non-ferrous metals.
- F. Other sources of chloride, which include fluxes, hydrochloric acid and washing materials
- G. Presence of anaerobic bacteria resulting in acidity and localised pitting corrosion.
- H. Incorrect, unsuitable or poorly applied or maintained water treatment products
- I. The formation of corrosion products deposited or plated out in the system.

Corrosion is most aggressive when there is a steady source of supporting reactant, e.g. fresh water make-up or re-aeration of the system water



2. Scale & Sludge

"Hardness" is the term which describes the concentration of calcium and magnesium salts dissolved in water, usually expressed as calcium carbonate (CaCO_3) equivalence (scale).

System areas most prone to failure due to fouling by scale or sludge include the boiler heat exchanger and circulator pump.

Fouling can also restrict flow through components such as thermostatic radiator valves, zone valves, drain valves, etc., and any parts of the system where there is a low water velocity or small pipe diameters (e.g. in radiators or fan convectors and microbore circuits).



Sludge accumulation will result in poor circulation and a decrease in system efficiency.

3. Microbiological Contamination

Microbiological organisms ranging from simple bacteria to fungal and yeast spores can cause problems when they enter a central heating system.



The greatest potential for microbiological proliferation exists in the feed and expansion cistern of open-vented systems. Here the temperature conditions are more favourable for bacterial growth and there is contact with the air.

Under-floor heating and other systems which operate at lower temperature (below 60 °C) can also be prone to microbiological fouling. Even the high temperature in the boiler heat exchanger might not be sufficient to kill all micro-organisms.

Anaerobic bacteria can thrive in both open and sealed systems fouled with corrosion and other debris, beneath deposits where the temperature might be lower and there is an absence of oxygen. This can give rise to microbiological corrosion of ferrous metals.

Treatment of Water

1. General

In most cases, the quality of the water used in the central heating system is determined by supply to the premises and this will vary across the United Kingdom.

Water treatment should be applied to all primary systems except for single feed indirect hot water cylinders.

Consideration should be given as to whether the water is hard or soft, as this might influence the approach to water treatment and the choice of proprietary product.

2. External

Naturally soft waters of low alkalinity or those supplied via a base-exchange resin softener have an increased potential for corrosion and, if they are to be used in any central heating system, a corrosion inhibitor specifically formulated for the purpose should be added and properly maintained.

3. Internal

To minimize the likelihood of corrosion, scale and sludge formation, the system water in any system should be treated with Altecnic C1 System Inhibitor, prior to this the system should be treated using Altecnic C3 System Clean to remove all system impurities as discussed above.

Bioocides may be dosed into static systems to prevent bacteria multiplying when there is a delay between pressure testing and commencement of flushing and chemical cleaning.



System Flushing Guide

Installing one of the Altecnic's range of Dirtmag™ system cleaners not only offers ongoing system protection with its unique design, it also allows draining and dosing of the system to be a much easier due to its specialist design features.

HEATING SYSTEM WATER WASH AND TREATMENT

<p>Stop the circulator, close the shut-off ball valves and drain the water out of the dirt separator.</p>	<p>Add C3 - CLEANER, using the dirt separator as a convenient point of access to the circuit.</p>	<p>Allow to circulate through the system for 1 hour. Stop the circulator and drain the circuit until clean water comes out.</p>	<p>Close the shut-off ball valves and fill with C1 - INHIBITOR via the dirt separator.</p>

Technical Bulletin

Water Treatment

DIRTMAGMINI

THE COMPACT MAGNETIC FILTER

The Dirtmag Mini™ dirt separator and strainer separates the impurities in heating systems to protect the boiler circulator and heat exchanger.

The removable magnet captures the ferro magnetic particles, whilst the mesh strainer and dirt separator capture the remaining debris. The compact design of this dirt separator strainer is ideal for installation under wall boilers, even in small spaces. The special inlet layout allows for vertical or horizontal installation, with angled or in-line connections as required.



DIRTMAGIQ

THE SMART MAGNETIC SEPARATOR

Dirtmag IQ™ system filters are the smart choice for efficient magnetic, non-magnetic and air separation.

Dirtmag IQ™ filters ensure maximum system protection and performance whilst enabling fast, simple and efficient servicing due to the external magnetic belt, full bore isolation valves and dosing point.

Visit www.altecnic.co.uk for more information.

